


ITEM	DESCRIPTION
1	AMMETER
2	MAINS SUPPLY HEALTHY -INDICATING LAMP
3	PUMP ON DEMAND -INDICATING LAMP
4	PUMP RUNNING -INDICATING LAMP
5	START FAILURE -INDICATING LAMP
6	EMERGENCY START -PUSHBUTTON
7	STOP/RESET -PUSHBUTTON
8	ISOLATOR/SWITCHFUSE OPERATING HANDLE

Kw RATING	HEIGHT	WIDTH	DEPTH
5.5	500	400	210
7.5	500	400	210
11	500	400	210
15	500	400	210
18.5	500	400	210
22	500	400	210
30	600	600	210
37	600	600	210
45	600	600	210
55	800	600	250
75	800	600	250



1st ISSUE	Len Porter	ID	26/06/04
REVISION	DRAWN BY	CHECKED BY	DATE
NORTH WEST SWITCHGEAR Ltd			
MORECAMBE		LANCASHIRE	
GENERAL ARRANGEMENT OF DIRECT ON LINE FIRE PUMP CONTROLLER(BSS306/EN12845 COMPLIANT)			
A3-18348			